

2430 E Street, N. W.
Washington, D. C.

10 July 1953

25X1A9a




Ref: Grounding Connections

25X1A9a

Dear Mr. [REDACTED]:

In response to your inquiry concerning reference connections, please be advised that the matter has been discussed with competent authorities, who are in agreement that the use of the Cadweld System is actually preferable to that specified. This being the case, approval may be given for the substitution, assuming that there is no extra cost involved.

Very truly yours,



25X1A9a